

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT

NO OBJECTION CERTIFICATE

LICENSE NO: 126/V/TBM/2023
C.R.NO :309 V/TBM/2023

Tambaram Fire and Rescue
Service Station.

DATE : 01.07.2023

Subject: Fire and rescue service department – Tambaram Fire and Rescue Service Station for purpose of no objection certificate – REG.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date : 14.09.2004
(2) G.O. No.123 School Edu (2) Dept, Date : 14.09.2004
(3) Date of Requisition letter from Dr.N.VIJAYAN
ZION INTERNATIONAL PUBLIC SCHOOL
Date – 23.06.2023

Based on the Govt. order mentioned above and the requisition letter given by the ZION INTERNATIONAL PUBLIC SCHOOL at NO': ZION AVENUE, PUTHUR, MAPPEDU, CHENNAI-600 126. Tamil Nadu the building and premises comprises Consisting of Ground+Three Floors owned/occupied ZION INTERNATIONAL PUBLIC SCHOOL Running in a GROUND+TWO FLOOR ONLY have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 30.06.2023 in the presence of Principal and that the school is granted NOC subject to the conditions stated below.


THIS CERTIFICATE DOES NOT VALID BY SWIMMING POOL IN THAT PREMISES AREA

THE ABOVE PREMISES INSPECTED BY STATION OFFICER FIRE & RESCUE SERVICES STATION ,G.TAMILPANDI ON 30 / 06 / 2023

CONDITIONS

1. The Proposed Building has Ground+Three Floors..
2. The Above Premises Height of the Building 16.21 Meters
3. Fire Safety Systems should be maintained in good working condition.
4. Mock drill to be conducted periodically with the help of local fire brigade.
5. Any erection of permanent or temporary structure should be intimated to this department.


PRINCIPAL
ZION INTERNATIONAL PUBLIC SCHOOL
PUTHUR, MAPPEDU, CHENNAI - 126.



Dr. N.Vijayan., M.A., M.Sc., M.Ed., M.L., Ph.D
(National Best Teacher Awardee)
Chairman
ZION INTERNATIONAL PUBLIC SCHOOL
ZION AVENUE, PUTHUR, CHENNAI - 600 126.

6. A trained Fire Service Person, preferably retired one should be appointed.
7. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.

- a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
 - d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e) Mock drill has to be conducted at regular intervals in consultation with the District Fire Officer, Fire and Rescue Services, South Chennai District at Ashok nagar, Chennai- 600 083
 - f) The classrooms should always be in the ground floor upto 3rd standards.
 - g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
 - h) The classroom doors/ windows shall always open outwards.
 - i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
 - j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
 - k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.
7. Downcomer system And Hose reel system should be provided

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.





STATION OFFICER
FIRE AND RESCUE SERVICE
TAMBARAM STATION, CHENNAI-600 047.

To:

Dr.N.VIJAYAN,
ZION INTERNATIONAL PUBLIC SCHOOL
NO': ZION AVENUE, PUTHUR,
MAPPEDU, CHENNAI-600 126..

CC : District Officer, South Chennai District


PRINCIPAL
ZION INTERNATIONAL PUBLIC SCHOOL
PUTHUR, MAPPEDU, CHENNAI - 126.


Dr. N.Vijayan, M.A., M.Sc., M.Ed., M.L., Ph.D
(National Best Teacher Awardee)
Chairman
ZION INTERNATIONAL PUBLIC SCHOOL
ZION AVENUE, PUTHUR, CHENNAI - 600 126.